

Certificate of Inspection

Certificate No: 24689

QUALITY FIRE PROTECTION LTD

FIRE EXTINGUISHER MAINTENANCE

This is to certify that an engineer of Quality Fire Protection has inspected the portable Fire Extinguishers at your premises, and that they have been serviced this day as required by British Standard B.S. 5306 Pt 3. Hose Reels B.S. EN 671

Name : Holly Bourne Village Hall

Location : Church Lane, Alton,
Hants, GU34 4HD

Engineer : L. AUDOIRE

Customer : _____

Date of Issue : December 2025

Expiry Date : December 2026

Telephone : 01489 787734

Mobile : 07961 124003 / 07951 889230

FETA CERT. NO: 3273

IFEDA CERT. NO: R02729 / R02730

QUALITY FIRE PROTECTION LTD

FIRE EXTINGUISHER MAINTENANCE

Check List

During the scheduled service of your fire equipment, your Quality Fire Protection representative will:

- 1 Service all extinguishers in accordance with BS 5306: PT 3 and recharge to BS: PT9 and to agreed contractual requirements.
- 2 Affix or mount your extinguishers in accordance with the recommendations of BS 5306 : Pt 3.
- 3 Recommend where necessary any additional fire fighting equipment that is required to ensure adequate protection for your premises as required by Fire Safety Regulations applying to your site.
- 4 Recommend the installation of fire safety signs as required by the Health and Safety (Safety Signs and Signals) Regulations 1996.
- 5 Issue this Certificate of Conformity following the service, providing that our Service Representative is satisfied that your fire fighting equipment is ready for use and provides adequate protection for your premises.