



Portable / Fixed Appliance

Equipment formal visual and combined inspection and test record

NA/PAT 6 4 3 0 0 0 0 0 0 0 1 2 8 8

1 Details of the Installation

Client	Mike Moulton	Installation	
Address	Holybourne Village Hall Church Lane Holybourne Alton Hampshire	Address	Holybourne Village Hall Church Lane Holybourne Alton Hampshire
Postcode	GU34 4HD	Postcode	GU34 4HD

Date of Test	17/01/2026
Date of Re-test	
Technician	Justin Davies
Test Equipment	KEWTECH SMARTPAT

2

Appliance No.	Description	Date of test	Serial / Identification No.	Class I / II	Fuse size	Visual Only	Earth Bond Ω	Insulation MΩ	Load KW	Function Run	Earth leak mA	RCD Check	Repair Code	Pass / Fail	Location
WES0101	KETTLE	17/01/2026		I	13		<0.1	>20		N/A	<0.04	N/A		✓	VILLAGE HALL
WES0102	EXT 1 WAY	17/01/2026		I	13		<0.11	>20		N/A		N/A		✓	VILLAGE HALL
WES0103	TEA URN	17/01/2026		I	13		<0.09	>20		N/A	<0.05	N/A		✓	VILLAGE HALL
WES0104	MICROWAVE	17/01/2026		I	13		<0.03	>20		N/A	<0.67	N/A		✓	VILLAGE HALL
WES0105	KETTLE LEAD	17/01/2026		I	13		<0.13	>20		N/A		N/A		✓	VILLAGE HALL
WES0106	PROJECTOR	17/01/2026		II	13			>20		N/A	<0.60	N/A		✓	VILLAGE HALL
WES0107	DOOR BELL	17/01/2026		II	0			>20		N/A	<0.03	N/A		✓	VILLAGE HALL
WES0108	EXT 2 WAY	17/01/2026		I	13		<0.11	>20		N/A		N/A		✓	VILLAGE HALL
WES0109	VACUUM CLEANER	17/01/2026		II	13			>20		N/A	<0.03	N/A		✓	VILLAGE HALL
WES0111	ROUTER	17/01/2026		II	0			>20		N/A	<0.04	N/A		✓	VILLAGE HALL
WES0112	FRIDGE	17/01/2026		I	13		<0.1	>20		N/A	<0.09	N/A		✓	VILLAGE HALL
WES0115	POWER SUPPLY	17/01/2026		II	0			>20		N/A	<0.04	N/A		✓	VILLAGE HALL
WES0116	KETTLE LEAD	17/01/2026		I	5		<0.01	>20		N/A		N/A		✓	VILLAGE HALL

Repair codes: 1 Damaged flex – Re-terminated 2 Damaged – Plug removed 3 Safety fault



Portable / Fixed Appliance

Equipment formal visual and combined inspection and test record

NA/PAT 6 4 3 0 0 0 0 0 0 0 1 2 8 8

2	Appliance No.	Description	Date of test	Serial / Identification No.	Class I / II	Fuse size	Visual Only	Earth Bond Ω	Insulation MΩ	Load KW	Function Run	Earth leak mA	RCD Check	Repair Code	Pass / Fail	Location
	WES0117	AMPLIFIER	17/01/2026		I	0		<0.05	>20		N/A	<0.04	N/A		✓	VILLAGE HALL
	WES0118	DVD PLAYER	17/01/2026		II	5			>20		N/A	<0.04	N/A		✓	VILLAGE HALL
	WES0119	VOICE/MUSIC MIXER	17/01/2026		II	5			>20		N/A	<0.06	N/A		✓	VILLAGE HALL
	WES0120	LIGHT BOX	17/01/2026		II	3			>20		N/A	<0.09	N/A		✓	VILLAGE HALL
	WES0121	LAPTOP CHARGER	17/01/2026		II	5			>20		N/A	<0.06	N/A		✓	VILLAGE HALL
	WES0122	KETTLE LEAD	17/01/2026		I	13		<0.03	>20		N/A		N/A		✓	VILLAGE HALL
	WES0123	PROJECTOR	17/01/2026		II	10			>20		N/A	<0.74	N/A		✓	VILLAGE HALL
	WES0124	EXT 1 WAY	17/01/2026		I	13		<0.25	>20		N/A		N/A		✓	VILLAGE HALL
	WES0128	LAMINATOR	17/01/2026		II	5			>20		N/A	<0.03	N/A		✓	PRE SCHOOL
	WES0130	PHONE CHARGER	17/01/2026		II	0			>20		N/A	<0.04	N/A		✓	PRE SCHOOL
	WES0131	PHONE CHARGER	17/01/2026		II	0			>20		N/A	<0.04	N/A		✓	PRE SCHOOL
	WES0133	PHONE CHARGER	17/01/2026		II	0			>20		N/A	<0.04	N/A		✓	PRE SCHOOL
	WES0134	RADIO	17/01/2026		II	13			>20		N/A	<0.04	N/A		✓	PRE SCHOOL
	WES0135	PHONE CHARGER	17/01/2026		II	0			>20		N/A	<0.04	N/A		✓	PRE SCHOOL
	WES0140	CHRISTMAS TREE LIGHTS	17/01/2026		II	0			>20		N/A	<0.04	N/A		✓	PRE SCHOOL
	WES0141	CHRISTMAS TREE LIGHTS	17/01/2026		II	0			>20		N/A	<0.03	N/A		✓	PRE SCHOOL
	WES0144	BATTERY CHARGER	17/01/2026		II	3			>20		N/A	<0.04	N/A		✓	PRE SCHOOL
	WES0145	POWER SUPPLY	17/01/2026		II	0			>20		N/A	<0.04	N/A		✓	PRE SCHOOL

Repair codes: 1 Damaged flex – Re-terminated 2 Damaged – Plug removed 3 Safety fault



Portable / Fixed Appliance

Equipment formal visual and combined inspection and test record

NA/PAT 6 4 3 0 0 0 0 0 0 0 1 2 8 8

2	Appliance No.	Description	Date of test	Serial / Identification No.	Class I / II	Fuse size	Visual Only	Earth Bond Ω	Insulation MΩ	Load KW	Function Run	Earth leak mA	RCD Check	Repair Code	Pass / Fail	Location
	WES0146	KETTLE	17/01/2026		I	13		<0.1	>20		N/A	<0.05	N/A		✓	WI
	WES0147	OVEN	17/01/2026		I	13		<0.05	>20		N/A	<0.13	N/A		✓	VILLAGE HALL
	WES0148	EXTRACTOR FAN	17/01/2026		II	3			>20		N/A	<0.04	N/A		✓	VILLAGE HALL
	WES0149	LAPTOP CHARGER	17/01/2026		II	5			>20		N/A	<0.06	N/A		✓	VILLAGE HALL
	WES0150	LAPTOP CHARGER	17/01/2026		II	3			>20		N/A	<0.04	N/A		✓	VILLAGE HALL
	WES0151	CHRISTMAS LIGHTS	17/01/2026		II	0			>20		N/A	<0.04	N/A		✓	VILLAGE HALL
	WES0152	CHARGER	17/01/2026		II	0			>20		N/A	<0.04	N/A		✓	VILLAGE HALL
	WES0153	EXTENSION LEAD	17/01/2026		I	13		<0.06	>20		N/A		N/A		✓	PRE SCHOOL
	WES0154	PRINTER	17/01/2026		II	3			>20		N/A	<0.03	N/A		✓	PRE SCHOOL
	WES0155	LAPTOP CHARGER	17/01/2026		II	5			>20		N/A	<0.06	N/A		✓	PRE SCHOOL
	WES0156	LAPTOP CHARGER	17/01/2026		II	5			>20		N/A	<0.05	N/A		✓	PRE SCHOOL
	WES0157	USB CHARGER	17/01/2026		II	0			>20		N/A	<0.04	N/A		✓	PRE SCHOOL
	WES0158	EXTENSION LEAD 50M	17/01/2026		I	13		<0.75	>20		N/A		N/A		✓	PRE SCHOOL
	WES0159	USB CHARGER	17/01/2026		II	13			>20		N/A	<0.04	N/A		✓	VILLAGE HALL
	WES0160	2 WAY BLOCK	17/01/2026		I	13		<0.01	>20		N/A		N/A		✓	VILLAGE HALL

Repair codes: 1 Damaged flex – Re-terminated 2 Damaged – Plug removed 3 Safety fault